



TC-5040

Test Report No. INHYD24064390902064315

ULR No. : TC504024000026935F

Report Issue Date: 02 Sep 2024

Test Report

Report Issued To: Manchester Global Mahavihara (MGM)

Rachloor Village Road, Bairagiguda Village, Kandukur Andol, Sy. No. 475, Srisailem Highway, , Hyderabad, Telangana, - 501359, India

BV Sample ID : 1681379
Group : Water, Residues in Water
Customer Reference** : PO
Sample receipt date : 26 Aug 2024
Date of registration : 26 Aug 2024
Date of commencing of testing : 26 Aug 2024
Date of Completion of testing : 29 Aug 2024
Sample Name** : RO Plant Water (Drinking Water)
Sample condition on receipt : Ambient
Sample quantity / Package : 5 Lt X 1 No + 1 Lt X 1 No
Batch No. / Lot No.** : NA

Sample Information: Sampling Done by Laboratory

Date of sampling : 26 Aug 2024
Sampling done by : Mr. John(BV Representative)
Sampling procedure : BV/SAR/F/SOP/001
Sampling Location : Rachloor X Road, Hyderabad

No.	Test Parameters	Unit	Test Results	Acceptable Limit as per IS 10500 : 2012	Permissible Limit in the absence of alternate source	Test Method	LOQ
Microbiological Analysis (Discipline: Biological)							
1	Coliforms	Per 100 ml	Absent	Shall not be detectable in any 100ml of sample	-	IS 15185 : 2016	-
2	E.coli	per 100 mL	Absent	Shall not be detectable in any 100ml of sample	-	IS 15185 : 2016	-
Pesticide Residues (Discipline: Chemical)							
3	2, 4 - D	µg/L	BLQ	30 max	No Relaxation	USEPA 515.1	0.01
4	O,P - DDD	µg/L	BLQ	1 max	No Relaxation	USEPA 508	0.01
5	O,P - DDE	µg/L	BLQ	1 max	No Relaxation	USEPA 508	0.01
6	O,P-DDT	µg/L	BLQ	1 max	No Relaxation	USEPA 508	0.01
7	P,P -DDD	µg/L	BLQ	1 max	No Relaxation	USEPA 508	0.01
8	P,P -DDE	µg/L	BLQ	1 max	No Relaxation	USEPA 508	0.01
9	P,P -DDT	µg/L	BLQ	1 max	No Relaxation	USEPA 508	0.01
10	Alachlor	µg/L	BLQ	20 max	No Relaxation	USEPA 525.2	0.01
11	Aldrin	µg/L	BLQ	0.03 max	No Relaxation	USEPA 508	0.01
12	Butachlor	µg/L	BLQ	125 max	No Relaxation	USEPA 8141A	0.01
13	Chlorpyrifos	µg/L	BLQ	30 max	No Relaxation	USEPA 8141A	0.01
14	Dieldrin	µg/L	BLQ	0.03 max	No Relaxation	USEPA 508	0.01
15	Alpha-HCH	µg/L	BLQ	0.01 max	No Relaxation	USEPA 508	0.01
16	Beta-HCH	µg/L	BLQ	0.04 max	No Relaxation	USEPA 508	0.01
17	Delta-HCH	µg/L	BLQ	0.04 max	No Relaxation	USEPA 508	0.01
18	Gamma-HCH	µg/L	BLQ	2 max	No Relaxation	USEPA 508	0.01
19	Alpha Endosulfan	µg/L	BLQ	0.4 max	No Relaxation	USEPA 508	0.01
20	Beta Endosulfan	µg/L	BLQ	0.4 max	No Relaxation	USEPA 508	0.01
21	Endosulfan sulfate	µg/L	BLQ	0.4 max	No Relaxation	USEPA 508	0.01





TC-5040

Test Report No. INHYD24064390902064315

ULR No. : TC504024000026935F

Report Issue Date: 02 Sep 2024

22	Ethion	µg/L	BLQ	3 max	No Relaxation	USEPA 1657A	0.01
23	Malathion	µg/L	BLQ	190 max	No Relaxation	USEPA 8141A	0.01
24	Monochrotophos	µg/L	BLQ	1 max	No Relaxation	USEPA 8141A	0.01
25	Parathion Methyl	µg/L	BLQ	0.3 max	No Relaxation	USEPA 8141A	0.01
26	Phorate	µg/L	BLQ	2 max	No Relaxation	USEPA 8141A	0.01
27	Isoproturon	µg/L	BLQ	9 max	No Relaxation	USEPA 532	0.01
28	Atrazine	µg/L	BLQ	2 max	No Relaxation	USEPA 8141A	0.01
Organoleptic and Physical parameters (Discipline: Chemical)							
29	Colour	Hazen	BLQ	5 max	15 max	IS 3025 (P-4) : 2021	1
30	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-5) : 2018	-
31	pH	-	7.06	6.5-8.5	No relaxation	IS 3025 (P-11) : 2022	1
32	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-7 & 8) : 2023	-
33	Turbidity	NTU	BLQ	1 max	5 max	IS 3025 (P-10) : 2023	1
34	Total Dissolved Solids	mg/L	11	500 max	2000 max	IS 3025 (P-16) : 2023	1
General Parameters Concerning substances undesirable in excessive Amount(Discipline: Chemical)							
35	Aluminium as Al	mg/L	BLQ	0.03 max	0.2 max	APHA 24th Ed. 3125	0.005
36	Ammonia (as Total ammonia-N)	mg/L	BLQ	0.5 max	No relaxation	APHA 24th Ed. 4500 NH3 F	0.1
37	Anionic Surface Active Agents (as MBAS)	mg/L	BLQ	0.2 max	1.0 max	Annex K of IS 13428 : 2005	0.1
38	Barium as Ba	mg/L	0.004	0.7 max	No relaxation	APHA 24th Ed. 3125	0.001
39	Boron as B	mg/L	0.009	0.5 max	2.4 max	APHA 24th Ed. 3125	0.005
40	Calcium	mg/L	2	75 max	200 max	IS 3025 (P-40) : 1991	1
41	Chloramines as Cl2	mg/L	BLQ	4.0 max	No relaxation	IS 3025 (P-26) : 2021	0.1
42	Chloride as Cl	mg/L	2	250 max	1000 max	IS 3025 (P-32) : 1988	1
43	Copper as Cu	mg/L	BLQ	0.05 max	1.5 max	APHA 24th Ed. 3125	0.001
44	Fluorides as F	mg/L	BLQ	1.0 max	1.5 max	APHA 24th Ed. 4500 F-D	0.1
45	Iron as Fe	mg/L	0.009	1.0 max	No relaxation	APHA 24th Ed. 3125	0.005
46	Magnesium as Mg	mg/L	BLQ	30 max	100 max	IS 3025 (P-46) : 2023	1
47	Manganese as Mn	mg/L	BLQ	0.1 max	0.3 max	APHA 24th Ed. 3125	0.001
48	Mineral oil	mg/L	BLQ	1.0 max	No relaxation	Cl:6 of IS 3025 (P-39):2021	0.1
49	Nitrate as NO3	mg/L	BLQ	45 max	No relaxation	APHA 24th Ed. 4500 NO3 B	0.1
50	Phenolic compounds AS C6H5OH	mg/L	BLQ	0.001 max	0.002 max	IS 3025 (P-43/Sec 1) : 2022	0.001
51	Residual free chlorine	mg/L	BLQ	0.2 min	1 min	IS 3025 (P-26) : 2021	0.1
52	Selenium as Se	mg/L	BLQ	0.01 max	No relaxation	APHA 24th Ed. 3125	0.001
53	Silver	mg/L	BLQ	0.1 max	No relaxation	APHA 24th Ed. 3125	0.001
54	Sulphates as SO4	mg/L	BLQ	200 max	400 max	IS 3025 (P-24) sec1: 2022	1
55	Sulphide as H2S	mg/L	BLQ	0.05 max	No relaxation	IS 3025 (P-29) : 2022	0.01
56	Total Alkalinity as CaCO3	mg/L	6	200 max	600 max	IS 3025 (P-23) : 2023	1
57	Total Hardness as CaCO3	mg/L	8	200 max	600 max	IS 3025 (P-21) : 2009	1
58	Zinc as Zn	mg/L	BLQ	5 max	15 max	APHA 24th Ed. 3125	0.005
Parameters Concerning Toxic Substances (Discipline : Chemical)							
59	Arsenic as As	mg/L	BLQ	0.01 max	No relaxation	APHA 24th Ed. 3125	0.001
60	Cadmium as Cd	mg/L	BLQ	0.003 max	No relaxation	APHA 24th Ed. 3125	0.001
61	Chromium as Cr	mg/L	BLQ	0.05 max	No relaxation	APHA 24th Ed. 3125	0.001
62	Cyanide as CN	mg/L	BLQ	0.05 max	No relaxation	IS 3025 (P-27)/Sec 1 : 2021	0.01





TC-5040



Test Report No. INHYD24064390902064315

ULR No. : TC504024000026935F

Report Issue Date: 02 Sep 2024

63	Lead as Pb	mg/L	BLQ	0.01 max	No relaxation	APHA 24th Ed. 3125	0.001
64	Mercury as Hg	mg/L	BLQ	0.001 max	No relaxation	APHA 24th Ed. 3125	0.001
65	Molybdenum as Mo	mg/L	BLQ	0.07 max	No relaxation	APHA 24th Ed. 3125	0.001
66	Nickel as Ni	mg/L	BLQ	0.02 max	No relaxation	APHA 24th Ed. 3125	0.001
67	Uranium as U	mg/L	BLQ	0.03 max	No relaxation	APHA 24th Ed. 3125	0.001
Trihalomethanes (Discipline : Chemical)							
68	Bromoform	mg/L	BLQ	0.1 max	No relaxation	EPA 524.3	0.0005
69	Bromodichloromethane	mg/L	BLQ	0.06 max	No relaxation	EPA 524.3	0.0005
70	Chloroform	mg/L	BLQ	0.2 max	No relaxation	EPA 524.3	0.0005
71	Dibromochloromethane	mg/L	BLQ	0.1 max	No relaxation	EPA 524.3	0.0005
Poly Chlorinated Biphenyl (Discipline: Chemical)							
72	Chlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
73	Dichlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
74	Heptachlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
75	Hexachlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
76	Octachlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
77	Pentachlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
78	Tetrachlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
79	Trichlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
Polynuclear Aromatic Hydrocarbons (Discipline: Chemical)							
80	Anthracene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
81	Acenaphthene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
82	Acenaphthylene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
83	Benzo (a) anthracene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
84	Benzo (a) Pyrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
85	Benzo (b) fluoranthrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
86	Benzo (g,h,i) perylene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
87	Benzo (k) Fluoranthrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
88	Chrysene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
89	Dibenz(a,h)anthracene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
90	Fluorene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
91	Fluoranthrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
92	Indeno(1,2,3-cd) pyrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
93	Naphthalene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
94	Pyrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
95	Phenanthrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
96	Toluene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001

Abbreviations: UOM: Unit of measurement, LOQ: Limit of Quantification, LOD: Limit of Detection, BLQ: Below limit of quantification, ND: Not Detected, NMT : Not More Than, NLT: Not Less Than, M: Microbiological limit that no sample unit may exceed. max: Maximum, min: Minimum.
Note: SAMPLE TESTED AS RECEIVED

The above sample meets IS 10500 : 2012 specifications with respective to the above tested parameters wherever applicable

Note-The statement of conformity was drawn based on APHA, IS 13428 & EPA 524.3.





Test Report No. INHYD24064390902064315

ULR No. : TC504024000026935F

Report Issue Date: 02 Sep 2024

Authorized Signatory

Authorized Signatory

Authorized Signatory

Rami Reddy Merugu

Mallikarjun Arelli

Ch. Raja Sekhar Reddy

Deputy Manager Instrumentation

Manager - Wet Chemistry

Manager - Lab Operations

DISCLAIMERS:

(1.) All services are rendered in accordance with Bureau Veritas General Terms and Conditions of Service available at General terms & Conditions - BVITS. [https://www.bureauveritas.co.in/sites/g/files/zyfpx556/files/media/document/General Conditions of Service - June 2021-BVITS-revised.pdf](https://www.bureauveritas.co.in/sites/g/files/zyfpx556/files/media/document/General%20Conditions%20of%20Service%20-%20June%202021-BVITS-revised.pdf). (2.) The information marked with (**) customer provided information for which the laboratory has no control. (3.) The test report shall not be reproduced in full and/or in part or be used for any promotional and/or publicity purpose without the prior written approval of the issuing authority. The laboratory is not responsible for the authenticity of photocopied test report. (4.) The test result relate only to the item tested at the time and place of testing. (5.) Issuance of a test report of Analysis is NOT an indication that the item(s) is (are) fit for any specific purpose nor does it release any other party from their respective obligations. The maximum amount Bureau Veritas shall be liable for under any circumstance are the fees paid by the Client for the services provided under its contract with the Client for services delivered herein. (6.) The test item will not be retained for more than 15 days for non-perishable and 7 days for perishable samples from the date of issue of test report except in case as required by applicable regulation. (7.) Bureau Veritas owes no duty to any third party with respect to the results contained herein nor does Bureau Veritas accept any liability whatsoever with respect to the use by any third party of any information set out in this test report. Any third party relying on or using this report is responsible for exercising its own independent judgement with regard to the information contained herein and releases Bureau Veritas from any liability arising therefrom. (8.) The tests marked with (#) are subcontracted. (9.) This report is a computer-generated document with electronic signature, hence does not require manual signature. (10.) The statement of compliance / decision rule is based on 95% confidence level for the reported expanded uncertainty. (11.) The opinion and interpretations expressed in the report is based on the results obtained from the tested item. (12.) Sample on receipt to lab was "found to be fit" for analysis.

--- End of Report ---



Sl.No.:

316787



Test Report No. INHYD24064390902064330

ULR No. : TC504024000026936F

Report Issue Date: 02 Sep 2024

Test Report

Report Issued To: Manchester Global Mahavihara (MGM)

Rachloor Village Road, Bairagiguda Village, Kandukur Andal, Sy. No. 475, Srisailem Highway, , Hyderabad, Telangana, - 501359, India

BV Sample ID : 1681380
Group : Water, Residues in Water
Customer Reference** : PO
Sample receipt date : 26 Aug 2024
Date of registration : 26 Aug 2024
Date of commencing of testing : 26 Aug 2024
Date of Completion of testing : 29 Aug 2024
Sample Name** : Dining Water (Drinking Water)
Sample condition on receipt : Ambient
Sample quantity / Package : 5 Lt X 1 No + 1 Lt X 1 No
Batch No. / Lot No.** : NA

Sample Information: Sampling Done by Laboratory

Date of sampling : 26 Aug 2024
Sampling done by : Mr. John(BV Representative)
Sampling procedure : BV/SAR/F/SOP/001
Sampling Location : Rachloor X Road, Hyderabad

No.	Test Parameters	Unit	Test Results	Acceptable Limit as per IS 10500 : 2012	Permissible Limit in the absence of alternate source	Test Method	LOQ
Microbiological Analysis (Discipline: Biological)							
1	Coliforms	Per 100 ml	Absent	Shall not be detectable in any 100ml of sample	-	IS 15185 : 2016	-
2	E.coli	per 100 mL	Absent	Shall not be detectable in any 100ml of sample	-	IS 15185 : 2016	-
Pesticide Residues (Discipline: Chemical)							
3	2, 4 - D	µg/L	BLQ	30 max	No Relaxation	USEPA 515.1	0.01
4	O,P - DDD	µg/L	BLQ	1 max	No Relaxation	USEPA 508	0.01
5	O,P - DDE	µg/L	BLQ	1 max	No Relaxation	USEPA 508	0.01
6	O,P-DDT	µg/L	BLQ	1 max	No Relaxation	USEPA 508	0.01
7	P,P -DDD	µg/L	BLQ	1 max	No Relaxation	USEPA 508	0.01
8	P,P -DDE	µg/L	BLQ	1 max	No Relaxation	USEPA 508	0.01
9	P,P -DDT	µg/L	BLQ	1 max	No Relaxation	USEPA 508	0.01
10	Alachlor	µg/L	BLQ	20 max	No Relaxation	USEPA 525.2	0.01
11	Aldrin	µg/L	BLQ	0.03 max	No Relaxation	USEPA 508	0.01
12	Butachlor	µg/L	BLQ	125 max	No Relaxation	USEPA 8141A	0.01
13	Chlorpyrifos	µg/L	BLQ	30 max	No Relaxation	USEPA 8141A	0.01
14	Dieldrin	µg/L	BLQ	0.03 max	No Relaxation	USEPA 508	0.01
15	Alpha-HCH	µg/L	BLQ	0.01 max	No Relaxation	USEPA 508	0.01
16	Beta-HCH	µg/L	BLQ	0.04 max	No Relaxation	USEPA 508	0.01
17	Delta-HCH	µg/L	BLQ	0.04 max	No Relaxation	USEPA 508	0.01
18	Gamma-HCH	µg/L	BLQ	2 max	No Relaxation	USEPA 508	0.01
19	Alpha Endosulfan	µg/L	BLQ	0.4 max	No Relaxation	USEPA 508	0.01
20	Beta Endosulfan	µg/L	BLQ	0.4 max	No Relaxation	USEPA 508	0.01
21	Endosulfan sulfate	µg/L	BLQ	0.4 max	No Relaxation	USEPA 508	0.01





TC-5040

Test Report No. INHYD24064390902064330

ULR No. : TC504024000026936F

Report Issue Date: 02 Sep 2024

22	Ethion	µg/L	BLQ	3 max	No Relaxation	USEPA 1657A	0.01
23	Malathion	µg/L	BLQ	190 max	No Relaxation	USEPA 8141A	0.01
24	Monochrotophos	µg/L	BLQ	1 max	No Relaxation	USEPA 8141A	0.01
25	Parathion Methyl	µg/L	BLQ	0.3 max	No Relaxation	USEPA 8141A	0.01
26	Phorate	µg/L	BLQ	2 max	No Relaxation	USEPA 8141A	0.01
27	Isoproturon	µg/L	BLQ	9 max	No Relaxation	USEPA 532	0.01
28	Atrazine	µg/L	BLQ	2 max	No Relaxation	USEPA 8141A	0.01
Organoleptic and Physical parameters (Discipline: Chemical)							
29	Colour	Hazen	BLQ	5 max	15 max	IS 3025 (P-4) : 2021	1
30	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-5) : 2018	-
31	pH	-	6.97	6.5-8.5	No relaxation	IS 3025 (P-11) : 2022	1
32	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-7 & 8) : 2023	-
33	Turbidity	NTU	BLQ	1 max	5 max	IS 3025 (P-10) : 2023	1
34	Total Dissolved Solids	mg/L	39	500 max	2000 max	IS 3025 (P-16) : 2023	1
General Parameters Concerning substances undesirable in excessive Amount(Discipline: Chemical)							
35	Aluminium as Al	mg/L	BLQ	0.03 max	0.2 max	APHA 24th Ed. 3125	0.005
36	Ammonia (as Total ammonia-N)	mg/L	BLQ	0.5 max	No relaxation	APHA 24th Ed. 4500 NH3 F	0.1
37	Anionic Surface Active Agents (as MBAS)	mg/L	BLQ	0.2 max	1.0 max	Annex K of IS 13428 : 2005	0.1
38	Barium as Ba	mg/L	0.004	0.7 max	No relaxation	APHA 24th Ed. 3125	0.001
39	Boron as B	mg/L	0.009	0.5 max	2.4 max	APHA 24th Ed. 3125	0.005
40	Calcium	mg/L	6	75 max	200 max	IS 3025 (P-40) : 1991	1
41	Chloramines as Cl2	mg/L	BLQ	4.0 max	No relaxation	IS 3025 (P-26) : 2021	0.1
42	Chloride as Cl	mg/L	6	250 max	1000 max	IS 3025 (P-32) : 1988	1
43	Copper as Cu	mg/L	BLQ	0.05 max	1.5 max	APHA 24th Ed. 3125	0.001
44	Fluorides as F	mg/L	BLQ	1.0 max	1.5 max	APHA 24th Ed. 4500 F-D	0.1
45	Iron as Fe	mg/L	0.010	1.0 max	No relaxation	APHA 24th Ed. 3125	0.005
46	Magnesium as Mg	mg/L	2	30 max	100 max	IS 3025 (P-46) : 2023	1
47	Manganese as Mn	mg/L	BLQ	0.1 max	0.3 max	APHA 24th Ed. 3125	0.001
48	Mineral oil	mg/L	BLQ	1.0 max	No relaxation	Cl:6 of IS 3025 (P-39):2021	0.1
49	Nitrate as NO3	mg/L	BLQ	45 max	No relaxation	APHA 24th Ed. 4500 NO3 B	0.1
50	Phenolic compounds AS C6H5OH	mg/L	BLQ	0.001 max	0.002 max	IS 3025 (P-43/Sec 1) : 2022	0.001
51	Residual free chlorine	mg/L	BLQ	0.2 min	1 min	IS 3025 (P-26) : 2021	0.1
52	Selenium as Se	mg/L	BLQ	0.01 max	No relaxation	APHA 24th Ed. 3125	0.001
53	Silver	mg/L	BLQ	0.1 max	No relaxation	APHA 24th Ed. 3125	0.001
54	Sulphates as SO4	mg/L	3	200 max	400 max	IS 3025 (P-24) sec1: 2022	1
55	Sulphide as H2S	mg/L	BLQ	0.05 max	No relaxation	IS 3025 (P-29) : 2022	0.01
56	Total Alkalinity as CaCO3	mg/L	20	200 max	600 max	IS 3025 (P-23) : 2023	1
57	Total Hardness as CaCO3	mg/L	26	200 max	600 max	IS 3025 (P-21) : 2009	1
58	Zinc as Zn	mg/L	0.006	5 max	15 max	APHA 24th Ed. 3125	0.005
Parameters Concerning Toxic Substances (Discipline : Chemical)							
59	Arsenic as As	mg/L	BLQ	0.01 max	No relaxation	APHA 24th Ed. 3125	0.001
60	Cadmium as Cd	mg/L	BLQ	0.003 max	No relaxation	APHA 24th Ed. 3125	0.001
61	Chromium as Cr	mg/L	BLQ	0.05 max	No relaxation	APHA 24th Ed. 3125	0.001
62	Cyanide as CN	mg/L	BLQ	0.05 max	No relaxation	IS 3025 (P-27)/Sec 1 : 2021	0.01



SI.No.: 316789



TC-5040

Test Report No. INHYD24064390902064330

ULR No. : TC504024000026936F

Report Issue Date: 02 Sep 2024

63	Lead as Pb	mg/L	BLQ	0.01 max	No relaxation	APHA 24th Ed. 3125	0.001
64	Mercury as Hg	mg/L	BLQ	0.001 max	No relaxation	APHA 24th Ed. 3125	0.001
65	Molybdenum as Mo	mg/L	BLQ	0.07 max	No relaxation	APHA 24th Ed. 3125	0.001
66	Nickel as Ni	mg/L	BLQ	0.02 max	No relaxation	APHA 24th Ed. 3125	0.001
67	Uranium as U	mg/L	BLQ	0.03 max	No relaxation	APHA 24th Ed. 3125	0.001
Trihalomethanes (Discipline : Chemical)							
68	Bromoform	mg/L	BLQ	0.1 max	No relaxation	EPA 524.3	0.0005
69	Bromodichloromethane	mg/L	BLQ	0.06 max	No relaxation	EPA 524.3	0.0005
70	Chloroform	mg/L	BLQ	0.2 max	No relaxation	EPA 524.3	0.0005
71	Dibromochloromethane	mg/L	BLQ	0.1 max	No relaxation	EPA 524.3	0.0005
Poly Chlorinated Biphenyl (Discipline: Chemical)							
72	Chlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
73	Dichlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
74	Heptachlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
75	Hexachlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
76	Octachlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
77	Pentachlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
78	Tetrachlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
79	Trichlorobiphenyl	mg/L	BLQ	0.0005 max	No relaxation	Annex M of IS 13428 : 2005	0.00001
Polynuclear Aromatic Hydrocarbons (Discipline: Chemical)							
80	Anthracene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
81	Acenaphthene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
82	Acenaphthylene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
83	Benzo (a) anthracene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
84	Benzo (a) Pyrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
85	Benzo (b) fluoranthrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
86	Benzo (g,h,i) perylene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
87	Benzo (k) Fluoranthrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
88	Chrysene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
89	Dibenz(a,h)anthracene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
90	Fluorene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
91	Fluoranthrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
92	Indeno(1,2,3-cd) pyrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
93	Naphthalene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
94	Pyrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
95	Phenanthrene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001
96	Toluene	mg/L	BLQ	0.0001 max	No relaxation	APHA 24th Ed. 6440 : 2017	0.00001

Abbreviations: UOM: Unit of measurement, LOQ: Limit of Quantification, LOD: Limit of Detection, BLQ: Below limit of quantification, ND: Not Detected, NMT : Not More Than, NLT: Not Less Than, M: Microbiological limit that no sample unit may exceed. max: Maximum, min: Minimum.

Note: SAMPLE TESTED AS RECEIVED

The above sample meets IS 10500 : 2012 specifications with respective to the above tested parameters wherever applicable

Note-The statement of conformity was drawn based on APHA, IS 13428 & EPA 524.3.



Sl.No.:

316790

Bureau Veritas India Testing Services Pvt Ltd
Formerly Bhagavathi Ana Labs Private
Limited 7-2-C7 & 8/4 Sanathnagar Industrial
Estate, Sanathnagar,
Hyderabad -500018,
India
E: csfoodlab.hyd@bureauveritas.com
T: +91 40 68144105/101



Test Report No. INHYD24064390902064330

ULR No. : TC504024000026936F

Report Issue Date: 02 Sep 2024

Authorized Signatory

Authorized Signatory

Authorized Signatory

Rami Reddy Merugu

Mallikarjun Arelli

Ch. Raja Sekhar Reddy

Deputy Manager Instrumentation

Manager - Wet Chemistry

Manager - Lab Operations

DISCLAIMERS:

(1.) All services are rendered in accordance with Bureau Veritas General Terms and Conditions of Service available at General terms & Conditions - BVITS. [https://www.bureauveritas.co.in/sites/g/files/zyfmx556/files/media/document/General Conditions of Service - June 2021-BVITS-revised.pdf](https://www.bureauveritas.co.in/sites/g/files/zyfmx556/files/media/document/General%20Conditions%20of%20Service%20-%20June%202021-BVITS-revised.pdf). (2.) The information marked with (**) customer provided information for which the laboratory has no control. (3.) The test report shall not be reproduced in full and/or in part or be used for any promotional and/or publicity purpose without the prior written approval of the issuing authority. The laboratory is not responsible for the authenticity of photocopied test report. (4.) The test result relate only to the item tested at the time and place of testing. (5.) Issuance of a test report of Analysis is NOT an indication that the item(s) is (are) fit for any specific purpose nor does it release any other party from their respective obligations. The maximum amount Bureau Veritas shall be liable for under any circumstance are the fees paid by the Client for the services provided under its contract with the Client for services delivered herein. (6.) The test item will not be retained for more than 15 days for non-perishable and 7 days for perishable samples from the date of issue of test report except in case as required by applicable regulation. (7.) Bureau Veritas owes no duty to any third party with respect to the results contained herein nor does Bureau Veritas accept any liability whatsoever with respect to the use by any third party of any information set out in this test report. Any third party relying on or using this report is responsible for exercising its own independent judgement with regard to the information contained herein and releases Bureau Veritas from any liability arising therefrom. (8.) The tests marked with (#) are subcontracted. (9.) This report is a computer-generated document with electronic signature, hence does not require manual signature. (10.) The statement of compliance / decision rule is based on 95% confidence level for the reported expanded uncertainty. (11.) The opinion and interpretations expressed in the report is based on the results obtained from the tested item. (12.) Sample on receipt to lab was "found to be fit" for analysis.

— End of Report —



Sl.No.:

316791



Test Report No. INHYD24064390902064347

ULR No. : TC504024000026938F

Report Issue Date: 02 Sep 2024

Test Report

Report Issued To: Manchester Global Mahavihara (MGM)

Rachloor Village Road, Bairagiguda Village, Kandukur Andar, Sy. No. 475, Srisailem Highway, , Hyderabad, Telangana, - 501359, India

BV Sample ID : 1681381
Group : Food and Agricultural Products
Customer Reference** : PO
Sample receipt date : 26 Aug 2024
Date of registration : 26 Aug 2024
Date of commencing of testing : 26 Aug 2024
Date of Completion of testing : 31 Aug 2024
Sample Name** : Chicken (Non-Veg)
Sample condition on receipt : 4°C
Sample quantity / Package : 250 gms
Batch No. / Lot No.** : NA

Sample Information: Sampling Done by Laboratory

Date of sampling : 26 Aug 2024
Sampling done by : Mr. John(BV Representative)
Sampling procedure : BV/SAR/F/SOP/001
Sampling Location : Rachloor X Road, Hyderabad

No.	Test Parameters	Unit	Test Results	Specifications as per WFS Guidelines	Test Method	LOQ
Microbiological Analysis (Discipline: Biological)						
1	Total Plate Count	cfu/g	4800	<10 ⁶	IS 5402 (P.1): 2021	10
2	Coliforms	cfu/g	<10	-	IS 5401(P.1): 2012	10
3	Staphylococcus Aureus	cfu/g	<10	<100	ISO 6888-1 : 2021	10
4	Salmonella	Per 25g	Absent	Absent	IS 5887 (P.3)sec.1 : 2020	-
5	Escherichia Coli	cfu/g	<10	<10	IS 5887 (P.1): 1976	10
6	Yeast & Moulds	cfu/g	<10	-	IS 5403: 1999	10
7	Bacillus Cereus	cfu/g	<10	<1000	IS 5887 (P.6) : 2012	10
8	Enterobacteriaceae	cfu/g	<10	<10000	ISO 21528 (P-2) : 2017	10
9	Clostridium Perfringens	cfu/g	<10	<1000	IS 5887(P.4):1999	10

Abbreviations: UOM: Unit of measurement, LOQ: Limit of Quantification, LOD: Limit of Detection, BLQ: Below limit of quantification, ND: Not Detected, NMT : Not More Than, NLT: Not Less Than, M: Microbiological limit that no sample unit may exceed. max: Maximum, min: Minimum.

Note: SAMPLE TESTED AS RECEIVED

The above sample meets World Food Safety Guidelines for Airline Catering Specifications with respective to the above tested parameters wherever applicable

Authorized Signatory

Ch. R. Reddy

Ch. Raja Sekhar Reddy

Manager – Lab Operations

DISCLAIMERS:

(1.) All services are rendered in accordance with Bureau Veritas General Terms and Conditions of Service available at General terms & Conditions - BVITS. [https://www.bureauveritas.co.in/sites/g/files/zypfnx556/files/media/document/General Conditions of Service - June 2021-BVITS-revised.pdf](https://www.bureauveritas.co.in/sites/g/files/zypfnx556/files/media/document/General%20Conditions%20of%20Service%20-%20June%202021-BVITS-revised.pdf). (2.) The information marked with (**) customer provided information for which the laboratory has no control. (3.) The test report shall not be reproduced in full and/or in part or be used for any promotional and/or publicity purpose without the prior written approval of the issuing authority. The laboratory is not responsible for the authenticity of photocopied test report. (4.) The test result relate only to the item tested at the time and place of testing. (5.) Issuance of a test report of Analysis is NOT an indication that the item(s) is (are) fit for any specific purpose nor does it release any other party from their respective obligations. The maximum amount Bureau Veritas shall be liable for under any circumstance are the fees paid by the Client for the services provided under its contract with the Client for services delivered herein. (6.) The test item will not be retained for more than 15 days for non-perishable and 7 days for perishable samples from the date of issue of test report except in case as required by applicable regulation. (7.) Bureau Veritas owes no duty to any third party with respect to the results contained herein nor does Bureau Veritas accept any liability whatsoever with respect to the use by any third party of any information set out in this test report. Any third party relying on or using this report is responsible for exercising its own independent judgement with regard to the information contained herein and releases Bureau Veritas from any liability arising therefrom. (8.) The tests marked with (#) are subcontracted. (9.) This report is a computer-generated document with electronic signature, hence does not require manual signature. (10.) The statement of compliance / decision rule is based on 95% confidence level for the reported expanded uncertainty. (11.) The opinion and interpretations expressed in the report is based on the results obtained from the tested item. (12.) Sample on receipt to lab was "found to be fit" for analysis.

— End of Report —



Sl.No.:

316792



Test Report No. INHYD24064390902064404

ULR No. : TC504024000026939F

Report Issue Date: 02 Sep 2024

Test Report

Report Issued To: Manchester Global Mahavihara (MGM)

Rachloor Village Road, Bairagiguda Village, Kandukur Andar, Sy. No. 475, Srisailem Highway, , Hyderabad, Telangana, - 501359, India

BV Sample ID : 1681382
Group : Food and Agricultural Products
Customer Reference** : PO
Sample receipt date : 26 Aug 2024
Date of registration : 26 Aug 2024
Date of commencing of testing : 26 Aug 2024
Date of Completion of testing : 31 Aug 2024
Sample Name** : Masoor Dal (Veg)
Sample condition on receipt : 4°C
Sample quantity / Package : 250 gms
Batch No. / Lot No.** : NA

Sample Information: Sampling Done by Laboratory

Date of sampling : 26 Aug 2024
Sampling done by : Mr. John(BV Representative)
Sampling procedure : BV/SAR/F/SOP/001
Sampling Location : Rachloor X Road, Hyderabad

No.	Test Parameters	Unit	Test Results	Specifications as per WFS Guidelines	Test Method	LOQ
Microbiological Analysis (Discipline: Biological)						
1	Total Plate Count	cfu/g	1600	<10 ⁶	IS 5402 (P.1): 2021	10
2	Coliforms	cfu/g	<10	-	IS 5401(P.1): 2012	10
3	Staphylococcus Aureus	cfu/g	<10	<100	ISO 6888-1 : 2021	10
4	Salmonella	Per 25g	Absent	Absent	IS 5887 (P.3)sec.1 : 2020	-
5	Escherichia Coli	cfu/g	<10	<10	IS 5887 (P.1): 1976	10
6	Yeast & Moulds	cfu/g	<10	-	IS 5403: 1999	10
7	Bacillus Cereus	cfu/g	<10	<1000	IS 5887 (P.6) : 2012	10
8	Enterobacteriaceae	cfu/g	<10	<10000	ISO 21528 (P-2) : 2017	10
9	Clostridium Perfringens	cfu/g	<10	<1000	IS 5887(P.4):1999	10

Abbreviations: UOM: Unit of measurement, LOQ: Limit of Quantification, LOD: Limit of Detection, BLQ: Below limit of quantification, ND: Not Detected, NMT : Not More Than, NLT: Not Less Than, M: Microbiological limit that no sample unit may exceed. max: Maximum, min: Minimum.
Note: SAMPLE TESTED AS RECEIVED

The above sample meets World Food Safety Guidelines for Airline Catering Specifications with respective to the above tested parameters wherever applicable

Authorized Signatory

Ch. R. Sekhar Reddy

Ch. Raja Sekhar Reddy

Manager – Lab Operations

DISCLAIMERS:

(1.) All services are rendered in accordance with Bureau Veritas General Terms and Conditions of Service available at General terms & Conditions - BVITS. [https://www.bureauveritas.co.in/sites/g/files/zypfnx556/files/media/document/General Conditions of Service - June 2021-BVITS-revised.pdf](https://www.bureauveritas.co.in/sites/g/files/zypfnx556/files/media/document/General%20Conditions%20of%20Service%20-%20June%202021-BVITS-revised.pdf). (2.) The information marked with (**) customer provided information for which the laboratory has no control. (3.) The test report shall not be reproduced in full and/or in part or be used for any promotional and/or publicity purpose without the prior written approval of the issuing authority. The laboratory is not responsible for the authenticity of photocopied test report. (4.) The test result relate only to the item tested at the time and place of testing. (5.) Issuance of a test report of Analysis is NOT an indication that the item(s) is (are) fit for any specific purpose nor does it release any other party from their respective obligations. The maximum amount Bureau Veritas shall be liable for under any circumstance are the fees paid by the Client for the services provided under its contract with the Client for services delivered herein. (6.) The test item will not be retained for more than 15 days for non-perishable and 7 days for perishable samples from the date of issue of test report except in case as required by applicable regulation. (7.) Bureau Veritas owes no duty to any third party with respect to the results contained herein nor does Bureau Veritas accept any liability whatsoever with respect to the use by any third party of any information set out in this test report. Any third party relying on or using this report is responsible for exercising its own independent judgement with regard to the information contained herein and releases Bureau Veritas from any liability arising therefrom. (8.) The tests marked with (#) are subcontracted. (9.) This report is a computer-generated document with electronic signature, hence does not require manual signature. (10.) The statement of compliance / decision rule is based on 95% confidence level for the reported expanded uncertainty. (11.) The opinion and interpretations expressed in the report is based on the results obtained from the tested item. (12.) Sample on receipt to lab was "found to be fit" for analysis.

--- End of Report ---



SI.No.: 316793